



**Grizzly Ranch CSD Consumer Confidence  
Report 2026**

## 2025 Consumer Confidence Report

### Water System Information

Water System Name: Grizzly Ranch Community Services District

Report Date: 6-15-26

Type of Water Source(s) in Use: Sub-Surface Wells

Name and General Location of Source(s): Well 3P2- Fox Sparrow Dr., Well 9M-Fox Sparrow Dr., Well 1P-Yarrow Ln.

Drinking Water Source Assessment Information: NA

Time and Place of Regularly Scheduled Board Meetings for Public Participation: Time and Place of Regularly Scheduled Board Meetings for Public Participation: Grizzly Ranch CSD Board Meetings are scheduled on a Fiscal Year quarterly basis in the months of September, December, March and June. Meetings typically are scheduled on the third Tuesday of each month. Meetings are typically scheduled at 9am. Regularly scheduled Board Meetings have been conducted remotely in hybrid fashion via zoom video and phone accessibility. Board Meeting schedules, agendas and minutes are available at: [www.grizzlyranchcsd.com](http://www.grizzlyranchcsd.com).

For More Information, Contact: Office Administrator Kristen Frasure, or General Manager Larry Smith at phone: 530-832-4716 or email: [grizzlyranchcsd@gmail.com](mailto:grizzlyranchcsd@gmail.com).

### About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2025, and may include earlier monitoring data.

### Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Grizzly Ranch CSD at 4456 Grizzly Rd. Portola, CA. 96122, (530) 832-4716 para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Grizzly Ranch CSD at 4456 Grizzly Rd. Portola, CA. 96122, (530) 832-4716

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Grizzly Ranch CSD at 4456 Grizzly Rd. Portola, CA. 96122, (530) 832-4716 o tumawag sa (530) 832-4716 para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Grizzly Ranch CSD at 4456 Grizzly Rd. Portola, CA. 96122 tại (530) 832-4716 để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Grizzly Ranch CSD at 4456 Grizzly Rd. Portola, Ca 96122 ntawm (530) 832-4716 rau kev pab hauv lus Askiv.

## Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter (µg/L)

Term	Definition
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

## Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

## Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

## About Your Drinking Water Quality

### Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do

not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

**Table 1. Sampling Results Showing the Detection of Coliform Bacteria**

Complete if bacteria are detected.

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
<i>E. coli</i>	2025 0	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

**Table 2. Sampling Results Showing the Detection of Lead and Copper**

Complete if lead or copper is detected in the last sample set.

Lead and Copper	Sample Date	No. of Samples Collected	90 <sup>th</sup> Percentile Level Detected	No. Sites Exceeding AL	Range of Results	AL	PHG	Typical Source of Contaminant
Lead (ppb)	8-24-23	5	0	0	0-0	15	0.2	Corrosion of household plumbing systems; Erosion of natural deposits
Copper (ppm)	8-24-23	5	0.331	0	0-0.331	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

**Table 3. Sampling Results for Sodium and Hardness**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	4-14-20	13	0	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	4-14-20	187	0	None	None	Sum of polyvalent cations present in the water,

						generally magnesium and calcium, and are usually naturally occurring
--	--	--	--	--	--	--

**Table 4. Detection of Contaminants with a Primary Drinking Water Standard**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
See Attachments for Breakdown						

**Table 5. Detection of Contaminants with a Secondary Drinking Water Standard**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
See Attachments for Breakdown						

**Table 6. Detection of Unregulated Contaminants**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects
See Attachments for Breakdown					

**Additional General Information on Drinking Water**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA’s Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who

have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Lead-Specific Language:** Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Grizzly Ranch CSD is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Grizzly Ranch CSD and Larry Smith at (530) 832-4716. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

**Additional Special Language for Nitrate, Arsenic, Lead, Radon, and *Cryptosporidium*:** While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic from Well 1P. We do not utilize this well for potable water, if GRCSO would need to operate this well for potable water we do possess means of filtration. The arsenic standard balances the current understanding of arsenic's possible health effects against the cost of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

State Revised Total Coliform Rule (RTCR): N/A

**Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement**

**Table 7. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement**

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
N/A				

**For Water Systems Providing Groundwater as a Source of Drinking Water**

**Table 8. Sampling Results Showing Fecal Indicator-Positive Groundwater Source Samples**

Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	2024 0	N/A	0	(0)	Human and animal fecal waste
Enterococci	2024 0	N/A	TT	N/A	Human and animal fecal waste
Coliphage	2024 0	NA	TT	N/A	Human and animal fecal waste

**Summary Information for Fecal Indicator-Positive Groundwater Source Samples, Uncorrected Significant Deficiencies, or Violation of a Groundwater TT**

**Special Notice of Fecal Indicator-Positive Groundwater Source Sample:** No Notes as per 0 detections.

**Special Notice for Uncorrected Significant Deficiencies:** No Notes as per 0 detections.

**Table 9. Violation of Groundwater TT**

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
N/A				

**For Systems Providing Surface Water as a Source of Drinking Water**

**Table 10. Sampling Results Showing Treatment of Surface Water Sources**

Treatment Technique <sup>(a)</sup> (Type of approved filtration technology used)	[Enter Treatment Technique]
Turbidity Performance Standards <sup>(b)</sup> (that must be met through the water treatment process)	Turbidity of the filtered water must: 1 – Be less than or equal to [Enter Turbidity Performance Standard to Be Less Than or Equal to 95% of Measurements in a Month] NTU in 95% of measurements in a month. 2 – Not exceed [Enter Turbidity Performance Standard Not to Be Exceeded for More Than Eight Consecutive Hours] NTU for more than eight consecutive hours. 3 – Not exceed [Enter Turbidity Performance Standard Not to Be Exceeded at Any Time] NTU at any time.

Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	N/A
Highest single turbidity measurement during the year	N/A
Number of violations of any surface water treatment requirements	N/A

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

**Summary Information for Violation of a Surface Water TT**

**Table 11. Violation of Surface Water TT**

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
N/A				

**Summary Information for Operating Under a Variance or Exemption**

N/A

**Summary Information for Revised Total Coliform Rule Level 1 and Level 2 Assessment Requirements**

If a water system is required to comply with a Level 1 or Level 2 assessment requirement that is not due to an *E. coli* MCL violation, include the following information below [22 CCR section 64481(n)(1)].

**Level 1 or Level 2 Assessment Requirement not Due to an *E. coli* MCL Violation**

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

During the past year we were not required to conduct 0 Level 1 Assessments. In addition, we were not required to take actions and we completed 0 of these actions.

During the past year [0] Level 2 assessments were required to be completed for our water system. [0] Level 2 assessments were completed. In addition, we were required to take [0] corrective actions and we completed [0] of these actions.

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "T", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD  
Sample Point: WELL\_1P

COUNTY: PLUMAS  
CLASS: CTGP

STATUS: Active

PCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD
CA3205006_001_001	GP	GRIZZLY RANCH CSD					WELL 1P												
		SECONDARY/GP																	
		1928 ALKALINITY, BICARBONATE	80.000		0.000		MG/L	*****	*****	4/18/2017	1	108		2026/04		81060011704180945G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1919 CALCIUM	302.000		0.000		MG/L	*****	*****	4/18/2017	1	108		2026/04		81060011704180945G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1929 ALKALINITY, CARBONATE		<	10.000		MG/L	*****	*****	4/18/2017	1	108		2026/04		81060011704180945G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1017 CHLORIDE	4.000		0.000		MG/L	500	*****	4/18/2017	4	108		2026/04		81060011704180945G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1905 COLOR		<	5.000		UNITS	15	*****	4/14/2020	4	108		2029/04		81060012004141156G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1022 COPPER, FREE		<	50.000		UG/L	1000	50	4/18/2017	5	108		2026/04		81060011704180945L	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2905 FOAMING AGENTS (SURFACTANTS)		<	0.100		MG/L	0.5	*****	4/18/2017	4	108		2026/04		81060011704180945G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1915 HARDNESS, TOTAL (AS CaCO3)	832.000		0.000		MG/L	*****	*****	4/18/2017	1	108		2026/04		81060011704180945G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1021 HYDROXIDE AS CALCIUM CARBONATE		<	10.000		MG/L	*****	*****	4/18/2017	1	108		2026/04		81060011704180945G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1028 IRON	690.000		30.000		UG/L	300	*****	1/6/2026	58	3	Interval	2026/04		2670065-002	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.7
		1031 MAGNESIUM	19.000		0.000		MG/L	*****	*****	4/18/2017	1	108		2026/04		81060011704180945G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1032 MANGANESE	543.000		3.000		UG/L	50	*****	1/6/2026	58	3	Interval	2026/04		2670065-002	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8



"Mod" field: "Interval", formerly seen as "M", means the sample frequency was modified. "Date", formerly seen as "T", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL\_1P

CLASS: CTGP

STATUS: Active

PSCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (\$)	UOM	MCL	DIR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD		
CA3205006_001_001		INORGANIC	1010		< 100.000		UG/L	1000	100	4/18/2017	5	108		2026/04		81060011 70418094 51	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)			
			1075		< 1.000		UG/L	4	1	4/18/2017	5	108		2026/04		81060011 70418094 51	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)			
			1015		< 1.000		UG/L	5	1	4/18/2017	5	108		2026/04		81060011 70418094 51	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)			
			1020		< 10.000		UG/L	50	10	4/18/2017	5	108		2026/04		81060011 70418094 51	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)			
			1080		< 1.000		UG/L	10	1	4/18/2017	2	36		2027/10		81060011 70418094 51	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)			
			1025		0.200		0.100		MG/L	2	0.1	4/18/2017	4	108		2026/04		81060011 70418094 51	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
			1035			< 1.000		UG/L	2	1	4/18/2017	5	108		2026/04		81060011 70418094 51	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
			1036			< 10.000		UG/L	100	10	4/18/2017	5	108		2026/04		81060011 70418094 51	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
			1039			< 2.000		UG/L	6	1	4/8/2025	7	36		2028/04		CH 2572871-001 1573	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 331.0	
			1045			< 5.000		UG/L	50	5	4/18/2017	5	108		2026/04		81060011 70418094 51	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
1085			< 1.000		UG/L	2	1	4/18/2017	5	108		2026/04		81060011 70418094 51	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)					
	NI	NITRATE/NITRITE																			
		1040		< 0.400		MG/L	10	0.4	4/8/2025	11	12		2026/04		CH 2572872-001 1573	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	SM 4500-NO3-F-00			

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "T", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD  
Sample Point: WELL\_1P  
COUNTY: PLUMAS  
CLASS: CTGP  
STATUS: Active

PSCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (%)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD		
CA3205006_001_001	NI	NITRATE/NITRITE																			
		1041	NITRITE	<	0.400		MG/L	1	0.4	4/11/2023	5	36		2026/04		CH 2372323-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	SM 4500-N03-F-00		
		RA	RADIOLOGICAL																		
		4109	GROSS ALPHA PARTICLE ACTIVITY	1.170		2.600	1.720	PCI/L	15	3	4/14/2020	2	108		2029/04		81060012 00414115 8R	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
		4030	RADIUM-228	<	0.624		0.570	PCI/L	-----	1	4/11/2023	5	108		2032/04		CH 2372322-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA RA-05	
		S1	REGULATED VOC																		
		2981	1,1,1-TRICHLOROETHANE	<	0.500			UG/L	200	0.5	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
		2988	1,1,2-TETRACHLOROETHANE	<	0.500			UG/L	1	0.5	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
		2985	1,1,2-TRICHLOROETHANE	<	0.500			UG/L	5	0.5	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
		2978	1,1-DICHLOROETHANE	<	0.500			UG/L	5	0.5	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
2977	1,1-DICHLOROETHYLENE	<	0.500			UG/L	6	0.5	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)				
2378	1,2,4-TRICHLORO BENZENE	<	0.500			UG/L	5	0.5	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)				
2968	O-DICHLOROBENZENE	<	0.500			UG/L	600	0.5	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)				

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "T", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL\_1P

STATUS: Active

CLASS: CTGP

PSCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (%)	UOM	MCL	DIR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD
CA3205006_001_001	S1	REGULATED VOC																	
	2980	1,2-DICHLOROETHANE	<	0.500			UG/L	0.5	0.5	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	2983	1,2-DICHLOROPROPANE	<	0.500			UG/L	5	0.5	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	2413	1,3-DICHLOROPROPENE	<	0.500			UG/L	0.5	0.5	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	2969	P-DICHLOROBENZENE	<	0.500			UG/L	5	0.5	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	2990	BENZENE	<	0.500			UG/L	1	0.5	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	2982	CARBON TETRACHLORIDE	<	0.500			UG/L	0.5	0.5	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	2380	CIS-1,2-DICHLOROETHYLENE	<	0.500			UG/L	6	0.5	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	2964	DICHLOROMETHANE	<	0.500			UG/L	5	0.5	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	2992	ETHYLBENZENE	<	0.500			UG/L	300	0.5	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	2251	METHYL TERT-BUTYL ETHER	<	3.000			UG/L	13	3	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	2989	CHLOROBENZENE	<	0.500			UG/L	70	0.5	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	

"Mod" field: "Interval", formerly seen as "W", means the sample Frequency was modified. "Date", formerly seen as "T", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

Sample Point:

COUNTY:

CLASS: CTGP

STATUS:

PCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (%)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD
CA3205006_001_001	S1	2996	STYRENE	<	0.500		UG/L	100	0.5	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2987	TETRACHLOROETHYLENE	<	0.500		UG/L	5	0.5	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2991	TOLUENE	<	0.500		UG/L	150	0.5	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2979	TRANS-1,2-DICHLOROETHYLENE	<	0.500		UG/L	10	0.5	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2984	TRICHLOROETHYLENE	<	0.500		UG/L	5	0.5	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2218	TRICHLOROFLUOROMETHANE	<	5.000		UG/L	150	5	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2904	TRICHLOROETHYLENE	<	10.000		UG/L	1200	10	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2976	VINYL CHLORIDE	<	0.500		UG/L	0.5	0.5	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2955	XYLENES, TOTAL	<	0.500		UG/L	1750	0.5	7/14/2020	2	72		2026/07		81060012 00714105 6V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "T", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD  
Sample Point: WELL\_3P2

COUNTY: PLUMAS  
CLASS: CTGP

STATUS: Active

PCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD
CA3205006_002_002	GP	GRIZZLY RANCH CSD					WELL 3P2												
		SECONDARY/GP																	
	1928	ALKALINITY, BICARBONATE	170.000	0.000	0.000		MG/L	*****	*****	4/14/2020	2	108		2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	1919	CALCIUM	47.000	0.000	0.000		MG/L	*****	*****	4/14/2020	2	108		2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	1929	ALKALINITY, CARBONATE		< 10.000	10.000		MG/L	*****	*****	4/14/2020	2	108		2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	1017	CHLORIDE	2.000	0.000	0.000		MG/L	500	*****	4/14/2020	3	108		2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	1905	COLOR		< 5.000	5.000		UNITS	15	*****	4/10/2025	4	108		2034/04		CH 2572904-001	2670	FGL ENVIRONMENTAL (CHICO)	3M 2120 B
	1022	COPPER, FREE		< 50.000	50.000		UG/L	1000	50	4/14/2020	3	108		2029/04		81060022 00414112 7L	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	2905	FOAMING AGENTS (SURFACTANTS)		< 0.100	0.100		MG/L	0.5	*****	4/14/2020	3	108		2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	1915	HARDNESS, TOTAL (AS CaCO3)	187.000	0.000	0.000		MG/L	*****	*****	4/14/2020	2	108		2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	1021	HYDROXIDE AS CALCIUM CARBONATE		< 10.000	10.000		MG/L	*****	*****	4/14/2020	2	108		2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	1028	IRON	9140.000		30.000		UG/L	300	*****	1/6/2026	62	3	Interval	2026/04		CH 2670065-003	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.7
	1031	MAGNESIUM	17.000	0.000	0.000		MG/L	*****	*****	4/14/2020	2	108		2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	1032	MANGANESE	290.000	0.500	0.500		UG/L	50	*****	1/6/2026	62	3	Interval	2026/04		CH 2670065-003	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8

"Mod" field: "Interval", formerly seen as "M", means the sample frequency was modified. "Date", formerly seen as "T", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL\_3P2

STATUS: Active

CLASS: CTGP

PCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (\$)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD
CA320506_002_002		SECONDARY/GP																	
		1920	ODOR	<	1.000		TON	3	-----	4/10/2025	4	108		2034/04		CH 2572904-001	2670	FGL ENVIRONMENTAL (CHICO)	SM 2150 B
		1925	PH		0.000		pH	-----	7/26/2011	4	108			2020/07	<b>DUE NOW</b>	81060021 10726092 00	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1050	SILVER	<	10.000		UG/L	100	-----	4/11/2023	5	108		2032/04		CH 2372113-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8
		1052	SODIUM		0.000		MG/L	-----	4/14/2020	2	108			2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1064	CONDUCTIVITY @ 25 C UNHDS/CM		0.000		UMHO/CM	1600	-----	4/14/2020	3	108		2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1055	SULFATE		0.500		MG/L	500	-----	4/14/2020	3	108		2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1930	TDS		0.000		MG/L	1000	-----	4/14/2020	5	108		2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		0100	TURBIDITY		0.350		NTU	5	-----	4/10/2025	4	108		2034/04		CH 2572904-001	2670	FGL ENVIRONMENTAL (CHICO)	SM 2130 B-01
		1095	ZINC	<	50.000		UG/L	5000	-----	4/14/2020	3	108		2029/04		81060022 00414112 7G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	<b>IO</b>	<b>INORGANIC</b>																	
	1002	ALUMINUM	<	50.000		UG/L	1000	50	4/11/2023	5	108		2032/04		CH 2372113-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8	
	1074	ANTIMONY, TOTAL	<	6.000		UG/L	6	6	4/11/2023	5	108		2032/04		CH 2372113-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8	
	1005	ARSENIC	<	1.000		UG/L	10	2	1/6/2026	63	108		2035/01		CH 2670065-003	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8	

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "T", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL\_3P2

CLASS: CTGP

STATUS: Active

PCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (\$)	UOM	MCL	DIR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD
CA3205006_002_002	IO	INORGANIC	1010		< 100.000		UG/L	1000	100	4/11/2023	5	108		2032/04		CH 2372113-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8
			1075		< 1.000		UG/L	4	1	4/11/2023	5	108		2032/04		CH 2372113-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8
			1015		< 1.000		UG/L	5	1	4/11/2023	5	108		2032/04		CH 2372113-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8
			1020		< 10.000		UG/L	50	10	4/11/2023	5	108		2032/04		CH 2372113-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8
			1080		< 1.000		UG/L	10	1	4/18/2017	2	36		2027/10		81060021 70418100	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
			1025		< 0.100		MG/L	2	0.1	4/14/2020	3	108		2029/04		81060022 00414112	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
			1035		< 1.000		UG/L	2	1	4/11/2023	5	108		2032/04		CH 2372113-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 245.1
			1036		< 10.000		UG/L	100	10	4/11/2023	5	108		2032/04		CH 2372113-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8
			1039		< 2.000		UG/L	6	1	4/8/2025	13	36		2028/04		CH 2572871-002	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 331.0
			1045		< 5.000		UG/L	50	5	4/11/2023	5	108		2032/04		CH 2372113-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8
1085		< 1.000		UG/L	2	1	4/11/2023	5	108		2032/04		CH 2372113-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8			
NI		NITRATE/NITRITE																	
1040		NITRATE		< 0.400		MG/L	10	0.4	4/8/2025	11	12		2026/04		CH 2572725-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	SM 4500-NO3-F-00	

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "T", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL\_3P2

STATUS: Active

CLASS: CTGP

PCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (\$)	UOM	MCL	DIR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD	
CA3205006_002_002	NI	NITRATE/NITRITE																		
		1041	<	0.400			MG/L	1	0.4	4/11/2023	5	36		2026/04		CH 2372320-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	SM 4500-N03-F-00	
		<b>RADIOLOGICAL</b>																		
S1	RA	GROSS ALPHA PARTICLE ACTIVITY																		
		4109	<	1.170			PCI/L	15	3	4/8/2025	2	108		2034/04		CH 2572723-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 900.0	
		4030		1.000			PCI/L	-----	1	2/14/2017	6	108		2026/02	<b>DUE NOW</b>	81060021 70214113 0R	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
<b>REGULATED VOC</b>																				
S1	RA	1,1,1-TRICHLOROETHANE																		
		2981	<	0.500			UG/L	200	0.5	7/14/2020	2	72		2026/07		81060022 00714112 2V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
		2988	<	0.500			UG/L	1	0.5	7/14/2020	2	72		2026/07		81060022 00714112 2V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
		2985	<	0.500			UG/L	5	0.5	7/14/2020	2	72		2026/07		81060022 00714112 2V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
		2978	<	0.500			UG/L	5	0.5	7/14/2020	2	72		2026/07		81060022 00714112 2V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
		2977	<	0.500			UG/L	6	0.5	7/14/2020	2	72		2026/07		81060022 00714112 2V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
		2378	<	0.500			UG/L	5	0.5	7/14/2020	2	72		2026/07		81060022 00714112 2V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
		2968	<	0.500			UG/L	600	0.5	7/14/2020	2	72		2026/07		81060022 00714112 2V	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "T", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL\_3P2

STATUS: Active

CLASS: CTGP

PSCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (\$)	UOM	MCL	DIR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD
CA3205006_002_002	S1	REGULATED VOC																	
	2980	1,2-DICHLOROETHANE	<	0.500		UG/L	0.5	0.5		7/14/2020	2	72		2026/07		81060022 00714112 ZV	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	2983	1,2-DICHLOROPROPANE	<	0.500		UG/L	5	0.5		7/14/2020	2	72		2026/07		81060022 00714112 ZV	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	2413	1,3-DICHLOROPROPENE	<	0.500		UG/L	0.5	0.5		7/14/2020	2	72		2026/07		81060022 00714112 ZV	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	2969	P-DICHLOROBENZENE	<	0.500		UG/L	5	0.5		7/14/2020	2	72		2026/07		81060022 00714112 ZV	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	2990	BENZENE	<	0.500		UG/L	1	0.5		7/14/2020	2	72		2026/07		81060022 00714112 ZV	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	2982	CARBON TETRACHLORIDE	<	0.500		UG/L	0.5	0.5		7/14/2020	2	72		2026/07		81060022 00714112 ZV	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	2380	CIS-1,2-DICHLOROETHYLENE	<	0.500		UG/L	6	0.5		7/14/2020	2	72		2026/07		81060022 00714112 ZV	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	2964	DICHLOROMETHANE	<	0.500		UG/L	5	0.5		7/14/2020	2	72		2026/07		81060022 00714112 ZV	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	2992	ETHYLBENZENE	<	0.500		UG/L	300	0.5		7/14/2020	2	72		2026/07		81060022 00714112 ZV	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	2251	METHYL TERT-BUTYL ETHER	<	3.000		UG/L	13	3		7/14/2020	2	72		2026/07		81060022 00714112 ZV	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	2989	CHLOROBENZENE	<	0.500		UG/L	70	0.5		7/14/2020	2	72		2026/07		81060022 00714112 ZV	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	

"Mod" field: "Interval", formerly seen as "W", means the sample Frequency was modified. "Date", formerly seen as "T", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY:

Sample Point:

STATUS:

CLASS: CTGP

PCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (\$)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD
CA3205006_002_002	S1	2996	STYRENE	<	0.500		UG/L	100	0.5	7/14/2020	2	72		2026/07		81060022 00714112 ZV	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2987	TETRACHLOROETHYLENE	<	0.500		UG/L	5	0.5	7/14/2020	2	72		2026/07		81060022 00714112 ZV	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2991	TOLUENE	<	0.500		UG/L	150	0.5	7/14/2020	2	72		2026/07		81060022 00714112 ZV	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2979	TRANS-1,2-DICHLOROETHYLENE	<	0.500		UG/L	10	0.5	7/14/2020	2	72		2026/07		81060022 00714112 ZV	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2984	TRICHLOROETHYLENE	<	0.500		UG/L	5	0.5	7/14/2020	2	72		2026/07		81060022 00714112 ZV	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2218	TRICHLOROFLUOROMETHANE	<	5.000		UG/L	150	5	7/14/2020	2	72		2026/07		81060022 00714112 ZV	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2904	TRICHLOROETHYLENE	<	10.000		UG/L	1200	10	7/14/2020	2	72		2026/07		81060022 00714112 ZV	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2976	VINYL CHLORIDE	<	0.500		UG/L	0.5	0.5	7/14/2020	2	72		2026/07		81060022 00714112 ZV	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		2955	XYLENES, TOTAL	<	0.500		UG/L	1750	0.5	7/14/2020	2	72		2026/07		81060022 00714112 ZV	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	

"Mod" field: "Interval", formerly seen as "M", means the sample frequency was modified. "Date", formerly seen as "T", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD  
Sample Point: WELL 9M

COUNTY: PLUMAS  
CLASS: CTGP

STATUS: Active

PCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (±)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD
CA3205006_003_003	GP	GRIZZLY RANCH CSD					WELL 9M												
		SECONDARY/GP																	
		1928 ALKALINITY, BICARBONATE	180.000		10.000		MG/L	*****	*****	4/8/2025	3	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	SM 2320 B
		1919 CALCIUM	67.000		1.000		MG/L	*****	*****	4/8/2025	3	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.7
		1929 ALKALINITY, CARBONATE		<	10.000		MG/L	*****	*****	4/8/2025	3	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	SM 2320 B
		1017 CHLORIDE	6.000		1.000		MG/L	500	*****	4/8/2025	4	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 300.0
		1905 COLOR	5.000		5.000		UNITS	15	*****	4/8/2025	4	108		2034/04		CH 2572870-001 ADD1	2670	FGL ENVIRONMENTAL (CHICO)	SM 2120 B
		1022 COPPER, FREE		<	50.000		UG/L	1000	50	4/8/2025	4	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8
		2905 FOAMING AGENTS (SURFACTANTS)		<	0.050		MG/L	0.5	*****	4/8/2025	4	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	SM 5540 C-00
		1915 HARDNESS, TOTAL (AS CaCO3)	237.000		1.000		MG/L	*****	*****	4/8/2025	3	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.7
		1021 HYDROXIDE AS CALCIUM CARBONATE		<	10.000		MG/L	*****	*****	4/8/2025	3	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	SM 2320 B
		1028 IRON	6790.000		30.000		UG/L	300	*****	1/6/2026	49	3	Interval	2026/04		CH 2670065-004	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.7
		1031 MAGNESIUM	17.000		1.000		MG/L	*****	*****	4/8/2025	3	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.7
		1032 MANGANESE	816.000		3.000		UG/L	50	*****	1/6/2026	49	3	Interval	2026/04		CH 2670065-004	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "T", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL 9M

STATUS: Active

CLASS: CTGP

PCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (\$)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD	
CA320506_003_003		<b>SECONDARY/GP</b>																		
		1920	ODOR	<	1.000		TON	3	-----	4/8/2025	4	108		2034/04		CH 2572870-001 ADD1	2670	FGL ENVIRONMENTAL (CHICO)	SM 2150 B	
		1925	PH	6.800	0.000		pH	-----	8/16/2016		3	108		2025/08	<b>DUE NOW</b>	81060031 1573 60816120 5G	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)		
		1050	SILVER	<	1.000		UG/L	100	-----	4/8/2025	4	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8	
		1052	SODIUM	14.000	1.000		MG/L	-----	4/8/2025		3	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.7	
		1064	CONDUCTIVITY @ 25 C UMHO5/CM	555.000	0.000		UMHO/CM	1600	-----	4/8/2025	4	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	SM 2510 B	
		1055	SULFATE	143.000	0.500		MG/L	500	-----	4/8/2025	4	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 300.0	
		1930	TDS	380.000	20.000		MG/L	1000	-----	4/8/2025	4	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	SM 2540 C	
		0100	TURBIDITY	3.200	0.100		NTU	5	-----	4/8/2025	4	108		2034/04		CH 2572870-001 ADD1	2670	FGL ENVIRONMENTAL (CHICO)	SM 2130 B-01	
		1095	ZINC	30.000	10.000		UG/L	5000	-----	4/8/2025	4	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.7	
		<b>IO</b>	<b>INORGANIC</b>																	
		1002	ALUMINUM	<	50.000		UG/L	1000	50		4/8/2025	4	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8
	1074	ANTIMONY, TOTAL	<	6.000		UG/L	6	6		4/8/2025	4	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8	
	1005	ARSENIC	<	1.000		UG/L	10	2		1/6/2026	49	108		2035/01		CH 2670065-004	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8	

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "T", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL 9M

STATUS: Active

CLASS: CTGP

PCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (\$)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD	
CA3205006_003_003	IO	<b>INORGANIC</b>																		
		1010	BARIUM		< 100.000			UG/L	1000	100	4/8/2025	4	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8
		1075	BERYLLIUM, TOTAL		< 1.000			UG/L	4	1	4/8/2025	4	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8
		1015	CADMIUM		< 1.000			UG/L	5	1	4/8/2025	4	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8
		1020	CHROMIUM	10.000		10.000		UG/L	50	10	4/8/2025	4	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8
		1080	CHROMIUM, HEX		< 1.000			UG/L	10	1	4/18/2017	2	36		2027/10		81060031 70418101	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
		1025	FLUORIDE		< 0.100			MG/L	2	0.1	4/8/2025	4	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 300.0
		1035	MERCURY		< 1.000			UG/L	2	1	4/8/2025	4	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 245.1
		1036	NICKEL		< 10.000			UG/L	100	10	4/8/2025	4	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8
		1039	PERCHLORATE		< 2.000			UG/L	6	1	4/8/2025	6	36		2028/04		CH 2572871-003	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 331.0
		1045	SELENIUM		< 5.000			UG/L	50	5	4/8/2025	4	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8
1085	THALLIUM, TOTAL		< 1.000			UG/L	2	1	4/8/2025	4	108		2034/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 200.8		
	<b>NI</b>	<b>NITRATE/NITRITE</b>																		
1040	NITRATE		< 0.400			MG/L	10	0.4	4/8/2025	10	12		2026/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	SM 4500-NO3-F-00		

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "T", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

STATUS: Active

Sample Point: WELL 9M

CLASS: CTGP

PSCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (%)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD
CA3205006_003_003	NI	NITRATE/NITRITE																	
		1041 NITRITE		<	0.400		MG/L	1	0.4	4/8/2025	5	36		2028/04		CH 2572870-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	SM 4500-M03-F-00
	RA	RADIOLOGICAL																	
		4109 GROSS ALPHA PARTICLE ACTIVITY		<	1.740	1.120	PCI/L	15	3	4/8/2025	2	108		2034/04		CH 2572726-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 900.0
		4030 RADIUM-228	1.000		0.200	0.400	PCI/L	-----	1	2/14/2017	4	108		2026/02	<b>DUE NOW</b>	81060031 70214120 3R	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	
	S1	REGULATED VOC																	
		2981 1,1,1-TRICHLOROETHANE		<	0.500		UG/L	200	0.5	5/13/2025	3	72		2031/05		CH 2574057-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2
		2988 1,1,2-TETRACHLOROETHANE		<	0.500		UG/L	1	0.5	5/13/2025	3	72		2031/05		CH 2574057-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2
		2985 1,1,2-TRICHLOROETHANE		<	0.500		UG/L	5	0.5	5/13/2025	3	72		2031/05		CH 2574057-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2
		2978 1,1-DICHLOROETHANE		<	0.500		UG/L	5	0.5	5/13/2025	3	72		2031/05		CH 2574057-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2
		2977 1,1-DICHLOROETHYLENE		<	0.500		UG/L	6	0.5	5/13/2025	3	72		2031/05		CH 2574057-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2
		2378 1,2,4-TRICHLORO BENZENE		<	0.500		UG/L	5	0.5	5/13/2025	3	72		2031/05		CH 2574057-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2
		2968 O-DICHLOROBENZENE		<	0.500		UG/L	600	0.5	5/13/2025	3	72		2031/05		CH 2574057-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2

"Mod" field: "Interval", formerly seen as "M", means the sample Frequency was modified. "Date", formerly seen as "T", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

COUNTY: PLUMAS

Sample Point: WELL 9M

CLASS: CTGP

STATUS: Active

PSCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (\$)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD
CA3205006_003_003	S1	REGULATED VOC																	
		2980	1,2-DICHLOROETHANE	<	0.500		UG/L	0.5	0.5	5/13/2025	3	72		2031/05		CH 2574057-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2
		2983	1,2-DICHLOROPROPANE	<	0.500		UG/L	5	0.5	5/13/2025	3	72		2031/05		CH 2574057-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2
		2413	1,3-DICHLOROPROPENE	<	0.500		UG/L	0.5	0.5	5/13/2025	3	72		2031/05		CH 2574057-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2
		2969	P-DICHLOROBENZENE	<	0.500		UG/L	5	0.5	5/13/2025	3	72		2031/05		CH 2574057-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2
		2990	BENZENE	<	0.500		UG/L	1	0.5	5/13/2025	3	72		2031/05		CH 2574057-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2
		2982	CARBON TETRACHLORIDE	<	0.500		UG/L	0.5	0.5	5/13/2025	3	72		2031/05		CH 2574057-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2
		2380	CIS-1,2-DICHLOROETHYLENE	<	0.500		UG/L	6	0.5	5/13/2025	3	72		2031/05		CH 2574057-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2
		2964	DICHLOROMETHANE	<	0.500		UG/L	5	0.5	5/13/2025	3	72		2031/05		CH 2574057-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2
		2992	ETHYLBENZENE	<	0.500		UG/L	300	0.5	5/13/2025	3	72		2031/05		CH 2574057-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2
		2251	METHYL TERT-BUTYL ETHER	<	3.000		UG/L	13	3	5/13/2025	3	72		2031/05		CH 2574057-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2
		2989	CHLOROBENZENE	<	0.500		UG/L	70	0.5	5/13/2025	3	72		2031/05		CH 2574057-001	1573	FGL ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2

"Mod" field: "Interval", formerly seen as "W", means the sample Frequency was modified. "Date", formerly seen as "I", means the Next Required sample date was modified.

System: GRIZZLY RANCH CSD

Sample Point:

COUNTY:

CLASS: CTGP

STATUS:

PCODE	GC	GROUP/ANALYTE	LAST RESULT	LESS THAN	REPORTING LEVEL	COUNTING ERROR (%)	UOM	MCL	DLR	LAST SAMPLE	COUNT OF RESULTS	FREQ MON THS	MOD	NEXT SAMPLE DUE	NOTES	SAMPLE ID	LAB ID	LAB NAME	METHOD
CA3205006_003_003	S1	2996	STYRENE	<	0.500		UG/L	100	0.5	5/13/2025	3	72		2031/05		CH 2574057-001	1573	ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2
		2987	TETRACHLOROETHYLENE	<	0.500		UG/L	5	0.5	5/13/2025	3	72		2031/05		CH 2574057-001	1573	ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2
		2991	TOLUENE	<	0.500		UG/L	150	0.5	5/13/2025	3	72		2031/05		CH 2574057-001	1573	ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2
		2979	TRANS-1,2-DICHLOROETHYLENE	<	0.500		UG/L	10	0.5	5/13/2025	3	72		2031/05		CH 2574057-001	1573	ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2
		2984	TRICHLOROETHYLENE	<	0.500		UG/L	5	0.5	5/13/2025	3	72		2031/05		CH 2574057-001	1573	ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2
		2218	TRICHLOROFLUOROMETHANE	<	5.000		UG/L	150	5	5/13/2025	3	72		2031/05		CH 2574057-001	1573	ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2
		2904	TRICHLOROETHYLENE	<	10.000		UG/L	1200	10	5/13/2025	3	72		2031/05		CH 2574057-001	1573	ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2
		2976	VINYL CHLORIDE	<	0.500		UG/L	0.5	0.5	5/13/2025	3	72		2031/05		CH 2574057-001	1573	ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2
		2955	XYLENES, TOTAL	<	0.500		UG/L	1750	0.5	5/13/2025	3	72		2031/05		CH 2574057-001	1573	ENVIRONMENTAL (SANTA PAULA, CA)	EPA 524.2

# Individual System Lead and Copper Rule Tracking Report

3205006      Grizzly Ranch CSD      Pop: 0      Eng:      Lead Action Level: 0.015 mg/L  
 Copper Action Level: 1.3 mg/L

Sample Date Begin/(End)	Monitoring Period	Sample Set ID	Number Required	Number Sampled	Lead 90th % (mg/L)	Copper 90th % (mg/L)	Action Taken	Action Type	Next Due Date	Next Due Freq	Comments
( 9/25/2007 )	YR2007			5	0.019	0.129			8/1/2008		Lead Exceedance
( 7/22/2008 )	YR2008			5	0.012	0.213			3/1/2009		No Exceedance
( 9/10/2009 )	YR2009			5	0.023	0.182			8/1/2010		Lead Exceedance - 5 samples due
( 7/20/2010 )	YR2010			5	0.026	0.314			3/1/2011		Lead Exceedance - 5 samples due
( 9/9/2011 )	YR2011			5	0.017	0.127			8/1/2012		Lead Exceedance - 5 samples due
( 9/24/2013 )	YR2013			5	0.014	0.431			8/1/2015		No Exceedance
9/16/2014 (10/24/2014)	YR2014			5	0.007	0.555			8/1/2017		No Exceedance
7/9/2017 ( 7/12/2017 )	YR2017			5	0.000	0.118			8/1/2020		No Exceedance
7/15/2020 ( 7/22/2020 )	YR2020			5	0.000	0.000			8/1/2023		No Exceedance
8/24/2023 ( 8/24/2023 )	YR2023		5	5	0.000	0.331			8/1/2026		No Exceedance

**Legend:**

Cit: Citation	1st 6: 1st initial 6-mo. round of monitoring	A1: 1st Annual monitoring	T1: 1st Triennial (3 yr) monitoring
EL: Enforcement letter	2nd 6: 2nd initial 6-mo. round of monitoring	A2: 2nd Annual monitoring	T2: 2nd Triennial (3 yr) monitoring
			T3: 3rd Triennial (3 yr) monitoring